



Project Summary

Entire House

Home InSight

Job: Website Example
 Date: 15 April 2012
 By: Sam Young

3150 E Hwy 34, Ste 209-226, Newnan, GA 30265 Phone: [M] 404-915-5321 Email: SherlockHomes@HomeInSight.biz Web: www.GABuilderEnergyServices.com

Project Information

For: Georgia Builder, High Performance Home Builders
 Greater Atlanta Metro Area, Peachtree City, GA 30271
 Phone: 404-915-5321
 Web: www.HomeInSight.biz
 Notes: Example Manual J, S, & D Reports

Design Information

Weather: Atlanta Hartsfield Intl AP, GA, US

Winter Design Conditions

Outside db 26 °F
 Inside db 70 °F
 Design TD 44 °F

Summer Design Conditions

Outside db 92 °F
 Inside db 75 °F
 Design TD 17 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 36 gr/lb

Heating Summary

Structure 27753 Btuh
 Ducts 2194 Btuh
 Central vent (50 cfm) **2342** Btuh
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 32289 Btuh

Sensible Cooling Equipment Load Sizing

Structure 16969 Btuh
 Ducts 1658 Btuh
 Central vent (50 cfm) **874** Btuh
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 0.96
 Equipment sensible load 18819 Btuh

Infiltration

Method Blower door
 Shielding / stories 3 (partial) / 1
 Pressure / AVF 50 Pa / 1000 cfm

	Heating	Cooling
Area (ft ²)	2043	2043
Volume (ft ³)	21152	21152
Air changes/hour	0.22	0.12
Equiv. AVF (cfm)	79	42

Latent Cooling Equipment Load Sizing

Structure 1805 Btuh
 Ducts 541 Btuh
 Central vent (50 cfm) 1188 Btuh
 Equipment latent load 3535 Btuh
 Equipment total load 22354 Btuh
 Req. total capacity at 0.70 SHR 2.2 ton

Heating Equipment Summary

Make Trane
 Trade XB13 WEATHERTRON
 Model 4TWB3030B1
 AHRI ref no4643670
 Efficiency 8.5 HSPF
 Heating input 28800 Btuh @ 47°F
 Heating output 27 °F
 Temperature rise 1000 cfm
 Actual air flow 0.033 cfm/Btuh
 Air flow factor 0.50 in H2O
 Static pressure
 Space thermostat

Cooling Equipment Summary

Make Trane
 Trade XB13 WEATHERTRON
 Cond 4TWB3030B1
 Coil *AM7A0B30H21
 AHRI ref no4643670
 Efficiency 12.0 EER, 14 SEER
 Sensible cooling 21000 Btuh
 Latent cooling 9000 Btuh
 Total cooling 30000 Btuh
 Actual air flow 1000 cfm
 Air flow factor 0.054 cfm/Btuh
 Static pressure 0.50 in H2O
 Load sensible heat ratio 0.85

Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





AED Assessment Entire House Home InSight

Job: Website Example
Date: 15 April 2012
By: Sam Young

3150 E Hwy 34, Ste 209-226, Newnan, GA 30265 Phone: [M] 404-915-5321 Email: SherlockHomes@HomeInSight.biz Web: www.GABuilderEnergyServices.com

Project Information


For: Georgia Builder, High Performance Home Builders
Greater Atlanta Metro Area, Peachtree City, GA 30271
Phone: 404-915-5321
Web: www.HomeInSight.biz

Design Conditions

Location:		Indoor:		Heating	Cooling
Atlanta Hartsfield Intl AP, GA, US		Indoor temperature (°F)		70	75
Elevation: 1027 ft		Design TD (°F)		44	17
Latitude: 34°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		40.4	36.3
Outdoor:	Heating	Cooling	Infiltration:		
Dry bulb (°F)	26	92			
Daily range (°F)	-	17 (M)			
Wet bulb (°F)	-	74			
Wind speed (mph)	15.0	7.5			

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 14.8%.

House has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh



Manual S Compliance Report

Entire House

Home InSight

Job: Website Example
 Date: 15 April 2012
 By: Sam Young

3150 E Hwy 34, Ste 209-226, Newman, GA 30265 Phone: [M] 404-915-5321 Email: SherlockHomes@HomeInSight.biz Web: www.GABuilderEnergyServices.com

Project Information

For: Georgia Builder, High Performance Home Builders
 Greater Atlanta Metro Area, Peachtree City, GA 30271
 Phone: 404-915-5321
 Web: www.HomeInSight.biz

Cooling Equipment

Design Conditions

Outdoor design DB: 91.5°F	Sensible gain: 18819 Btuh	Entering coil DB: 75.9°F
Outdoor design WB: 74.0°F	Latent gain: 3535 Btuh	Entering coil WB: 63.1°F
Indoor design DB: 75.0°F	Total gain: 22354 Btuh	
Indoor RH: 50%	Estimated airflow: 1000 cfm	

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP
 Manufacturer: Trane Model: 4TWB3030B1+*AM7A0B30H21
 Actual airflow: 1000 cfm
 Sensible capacity: 22746 Btuh 121% of load
 Latent capacity: 5678 Btuh 161% of load
 Total capacity: 28424 Btuh 127% of load SHR: 80%

Heating Equipment

Design Conditions

Outdoor design DB: 25.8°F	Heat loss: 32289 Btuh	Entering coil DB: 67.6°F
Indoor design DB: 70.0°F		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP
 Manufacturer: Trane Model: 4TWB3030B1+*AM7A0B30H21
 Actual airflow: 1000 cfm
 Output capacity: 20344 Btuh 63% of load Capacity balance: 38 °F
 Supplemental heat required: 11945 Btuh Economic balance: -99 °F


Backup equipment type: Elec strip
 Manufacturer: Model:
 Actual airflow: 1000 cfm
 Output capacity: 32289 Btuh 100% of load Temp. rise: 0 °F

The above equipment was selected in accordance with ACCA Manual S.



Level 1

50'-0"



Job #: Website Example
Performed by Sam Young for:

Georgia Builder
Greater Atlanta Metro Area
Peachtree City, GA 30271
Phone: 404-915-5321
www.HomeInSight.biz

Home InSight

3150 E Hwy 34, Ste 209-226
Newnan, GA 30265
Phone: [M] 404-915-5321
www.GABuilderEnergyServices.com SherlockHom...

Scale: 1 : 97

Page 1
Right-Suite@ Universal 2012
12.0.00 RSU13835
2012-Apr-15 18:44:53
...bsiteManuals J S T D Report.rup



Duct System Summary

Entire House

Home InSight

Job: Website Example
 Date: 15 April 2012
 By: Sam Young

3150 E Hwy 34, Ste 209-226, Newnan, GA 30265 Phone: [M] 404-915-5321 Email: SherlockHomes@HomeInSight.biz Web: www.GABuilderEnergyServices.com

Project Information

For: Georgia Builder, High Performance Home Builders
 Greater Atlanta Metro Area, Peachtree City, GA 30271
 Phone: 404-915-5321
 Web: www.HomeInSight.biz

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0.23 in H2O	0.23 in H2O
Available static pressure	0.27 in H2O	0.27 in H2O
Supply / return available pressure	0.17 / 0.10 in H2O	0.17 / 0.10 in H2O
Lowest friction rate	0.093 in/100ft	0.093 in/100ft
Actual air flow	1000 cfm	1000 cfm
Total effective length (TEL)		289 ft

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bedroom 2	c 1831	93	98	0.113	6.0	0x0	VIFx	30.0	120.0	st2
Bedroom 3	h 3167	106	95	0.112	6.0	0x0	VIFx	20.3	130.0	st2
Foyer	h 3029	101	81	0.116	6.0	0x0	VIFx	35.0	110.0	st2
Hall Bath	c 547	23	29	0.122	4.0	0x0	VIFx	3.5	135.0	st2
Kitchen	c 803	10	43	0.100	4.0	0x0	VIFx	34.6	135.0	st1
Kitchen-A	c 803	10	43	0.122	4.0	0x0	VIFx	14.0	125.0	st2
Laundry	c 1578	57	85	0.096	5.0	0x0	VIFx	55.2	120.0	st1
Living Room	h 4158	139	130	0.093	7.0	0x0	VIFx	51.0	130.0	st1
Living Room-A	h 4158	139	130	0.120	7.0	0x0	VIFx	26.3	115.0	st2
Master Bath	c 1604	68	86	0.114	5.0	0x0	VIFx	13.8	135.0	st1
Master Bedroom	h 3883	130	109	0.107	6.0	0x0	VIFx	42.3	115.0	st1
Master Hall	h 2939	98	56	0.102	5.0	0x0	VIFx	46.3	120.0	st1
WIC	h 768	26	14	0.119	4.0	0x0	VIFx	6.8	135.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st2	Peak AVF	472	476	0.112	606	12.0	0 x 0	ShtMetl	
st1	Peak AVF	528	524	0.093	672	12.0	0 x 0	ShtMetl	

Bold/italic values have been manually overridden

Return Branch Detail Table

Name	Grill Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb4	14x3	106	95	104.5	0.097	396	7.0	0x 0		VIFx	rt1
rb2	0x0	93	98	108.4	0.093	368	7.0	0x 0		VIFx	rt1
rb3	0x0	577	598	78.3	0.129	559	14.0	0x 0		VIFx	
rb1	0x0	224	210	104.3	0.097	506	9.0	0x 0		VIFx	

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt1	Peak AVF	199	193	0.093	570	8.0	0 x 0	VinIFlx	

Bold/italic values have been manually overridden